



**Cherokee County Fire & Emergency Services  
Community Risk Reduction Division  
Fire Marshal's Office  
1130 Bluffs Parkway Canton, Georgia, 30114  
678-493-6290 office  
[firemarshal@cherokeega.com](mailto:firemarshal@cherokeega.com)**

## **Final Plat Inspection Requirements**

The following must be completed in order to receive approval:

The Final Plat plan review must include the following:  
Fire Hydrant GPS Coordinates in the State Plane, Northern and Easting Format.

The Water Flow Data:  
GPM, Static Pressure, Residual Pressure and the Location of the Fire Hydrant flowed.

Once the Final Plat plan review is approved then will go inspect the final plat.

1. Road must have an approved surface.
2. Fire hydrants must be operational (have a water flow)
3. Hydrants facing the correct direction
4. Street signs must be in, permanent or temporary weatherproof.
5. "Dead end streets over 150' must have approved FD turnaround"

This list is not all inclusive.

We will be inspecting the property according to the approved Final Plat.

If the first inspection fails there will be a \$150.00 re-inspection fee, each re-inspection after that there will be a \$200.00 fee.